

汚濁負荷量測定記録表

測定年月日	測定者	計 測						汚濁負荷量			備考
		場所	時刻	COD (mg/L)	N (mg/L)	P (mg/L)	排水量 (m <sup>3</sup> /日)	COD (Kg/日)	N (Kg/日)	P (Kg/日)	
H19.1.15	○×△		10:31	4.2	2.2	0.51	121	0.0	0.0	0.00	
H19.1.31	○×△		10:16	4.6	2.6	0.49	144	0.0	0.0	0.00	
平均				4.4	2.4	0.50	133	0.0	0.0	0.00	
H19.2.13	○×△		10:10	3.1	3.1	0.75	134	0.0	0.0	0.00	
H19.2.26	○×△		9:55	5.2	2.9	0.85	168	0.0	0.0	0.00	
平均				4.2	3.0	0.80	151	0.0	0.0	0.00	
H19.3.10	○×△		10:52	6.1	2.6	0.46	112	0.0	0.0	0.00	
H19.3.25	○×△		10:30	4.0	2.8	0.45	130	0.0	0.0	0.00	
平均				5.1	2.7	0.46	121	0.0	0.0	0.00	

使いやすいように  
記入方法を工夫し  
ていただいてかま  
いません。

備考 1 本紙の記載にあたっては、指定項目ごとに作成すること。  
 2 指定項目の別の項、汚染状態の項及び汚濁負荷量の項には、指定項目について記載すること。  
 3 汚濁負荷量の算定の基礎となった資料を合わせて保存すること。